



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

Extended

FOR OFFICE USE ONLY

Facility # 2-008881
Permit # 01192-2013UPG
Request Rec'd 11/21/2013
Amended Date
Approval Date 11/21/2013 JC
Permit Expires 11/21/2014

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Amcor Flexibles 1919 Butterfield Rd. Mundelein, IL 60060 Contact: Warren Liljegren (847) 362-9000	(2) FACILITY - name and address where tanks are located: Amcor Flexibles 1919 S Butterfield Rd Mundelein, Lake Co., IL Contact: Dan Stephan (847) 362-9000
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired:* (TK # 2, 3) - 2,000 gallons
 - (b) Type of tanks:*
 - (c) Type of piping:* (TK # 2, 3) - (Installing) Positive Shutoff Valves at the submersible sumps only. , (TK # 2, 3) - (Installing) Submersible Sumps containment FRP to replace the existing sumps (this will include small sections of piping / fittings in the localized area of the new submersible sumps to accommodate the replacement).
 - (d) Product to be stored in each tank:* (TK # 2) - Alcohol, (TK # 3) - Hazardous Substance (MEK)
 - (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
 - (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
 - (g) Spill containment devices, piping, and dispenser containment devices:*
 - (h) Overfill prevention devices:*
 - (i) Manway accessible at grade:*
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES:** Extension request was received 05/15/14 (the extension fees were paid through check #38368 which was originally allocated for a permit that was later cancelled by this office). The underground storage tank system for tank #2 must be compatible with alcohol, and #3 must be compatible with MEK as indicated in section 175.415 of Title 41 of the Illinois Administrative Code.

<u>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Interstate Pump & Tank, Inc. 901 Niagara Street Waukesha, WI 53186	Contact Person: Dan McMahon Phone: (262) 524-8494 Contractor Registration # IL-1171 Exp. 05/07/2014
--	---

Sincerely,

Jim Coffey

