



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

**Section of piping removal / dispenser removal
only**

FOR OFFICE USE ONLY

Facility # 2-039572
Permit # 00465-2014REM
Request Rec'd 05/22/2014
Amended Date
Approval Date 5/22/2014 JC
Permit Expires 11/24/2014

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Meijer Great Lakes Limited Partnership 2929 Walker Avenue, NW Grand Rapids, MI 49544-9428 Contact: Lyle Livasy (616) 453-6711	(2) FACILITY - name and address where tanks are located: Meijer Gas & C Store #182 865 South Randall Road St. Charles, Kane Co., IL Contact: Dave Hayward (630) 762-7209 Ext. 479
---	--

(3) REMOVAL OF TANKS:

- (a) *Number and size of tanks being removed:* (TK # 3) - 8,000 gallons
 - (b) *Description/location of piping being removed:* **See contingencies section and site plan.**
 - (c) *Product stored in each tank:* (TK # 3) - Diesel Fuel
 - (d) *Reason of tanks being removed:* **Tanks will remain existing.**
 - (e) *If tank(s) is leaking, indicate IEMA incident number:*
 - (f) *Date each tank was last used:* (TK # 3)
- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.
- (5) **SPECIAL CONTINGENCIES:** **Removing short section of piping only (approximately 3') within the immediate area of dispenser # 11/12 to accommodate the extension of the existing piping to dispenser # 13/14 only (the existing lone diesel dispenser # 11/12 will be removed). The tank and remainder of the piping will remain. See permit and site plan for permit #00448-2014UPG for more complete details of this job.**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Hoyt Ary Phone: (708) 243-9081 Contractor Registration # IL-002275 Exp. 06/10/2015
---	--

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)