

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Petroleum and Chemical Safety 1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)785-1020 FOR OFFICE USE ONLY Facility # 7-043788 Permit # 00487-2014INS Request Rec'd 05/27/2014 Amended Date Approval Date 5/27/2014 JC Permit Expires 12/1/2014

## Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| (1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: | (2) <u>FACILITY</u> - name and address where tanks are located:                |
|---|--|
| Russell Oil Company<br>200 E Main, PO Box 73<br>Galatia, IL 62935               | ROC Convenience Store<br>1100 W. Broadway<br>Johnston City, Williamson Co., IL |
| Contact: Terry Stevens (618) 268-4722   | Contact: Becki Grant (618) 926-9180  |

## (3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 5) 20,000 gallons
- (b) Type of tanks: (TK # 5) (Installing) Composite Double Wall Glasteel II
- (c) Type of piping: (TK # 5) (Installing) Flexible Double Wall A.P.T. Poly Tech P175SC for the product piping., (TK # 5) (Installing) Fiberglass Single Wall Piping Ameron for vent piping and for the future DEF product piping from a new transition sump to all dispensers.
- (d) Product to be stored in each tank: (TK # 5) Diesel Fuel
- (e) Type of leak detection being used:
  - *Tank:* (TK # 5) (Installing) Automatic Tank Gauging Veeder Root TLS 350, (TK # 5) (Installing) Interstitial Monitoring Veeder Root TLS 350
  - *Piping:* (TK # 5) (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350, (TK # 5) (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at the submersible sump and at all dispenser sumps.
- (f) Corrosion Protection being used:

Tank: (TK # 5) - (Installing) Composite Non-Corrosive

**Piping:** (TK # 5) - (Installing) Fiberglass Non-Corrosive vent piping and for the product piping related to the future DEF tank, (TK # 5) - (Installing) Flexible Non-Corrosive product piping.

- (g) Spill containment devices, piping and dispenser containment devices: (TK # 5) (Installing) Manhole Pre-manufactured OPW 1-2100-DEVR
- (h) Overfill prevention devices: (TK # 5) (Installing) Overfill Drop Tube Valve OPW 71SO
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at <u>www.sfm.illinois.gov</u> or by calling (217)785-1020.
- (5) <u>GENERAL REQUIREMENTS:</u> There shall be a minimum of two manufactured slotted or perforated observation wells of at lease 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.
- (6) <u>SPECIAL CONTINGENCIES</u>: This permit replaces permit #01182-2013INS. Due to weather conditions, the contractor could not make the scheduling deadline. All equipment and site plan stays as original. There will be a DEF tank installed in the future (at present, there will only be product lines run for this DEF tank from a new transition sump to each dispenser).

## (7) PERSON, FIRM OR COMPANY PERFORMING WORK:

Robert Ellis & Sons 1703 North 7th Street Murphysboro, IL 62966 Contact Person: Robert Ellis Phone: (618) 713-0765

Contractor Registration # IL-980

Exp. 03/23/2016

Sincerely,

Janu & Coffey

Jim Coffey

cc: Storage Tank Safety Specialist -Fire Department -Division File (Rev. - 9/10)