



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

<u>FOR OFFICE USE ONLY</u>
Facility # 2-040346
Permit # 00490-2014UPG
Request Rec'd 05/28/2014
Amended Date
Approval Date 5/28/2014 JC
Permit Expires 12/1/2014

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Meijer Great Lakes Limited Partnership 2929 Walker Avenue, NW Grand Rapids, MI 49544-9428</p> <p>Contact: Lyle Livasy (616) 453-6711</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Meijer Gas Station #206 490 S Randall Rd Algonquin, McHenry Co., IL</p> <p>Contact: Dianna Murray (847) 960-7829</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 3) - 8,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 3) - (Installing) partial Fiberglass Double Wall NOV Fiberglass Systems Red Thread IIA fiberglass piping (approximately 8') to extend the existing diesel piping run from the existing stand alone diesel dispenser to the next closest dispenser (the existing diesel stand alone dispenser and sump will be removed).
- (d) *Product to be stored in each tank:* (TK # 3) - Diesel Fuel
- (e) *Type of leak detection being used:*
Tank:
Piping: (TK # 3) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at the closest dispenser near the discontinued stand alone diesel dispenser only.
- (f) *Corrosion Protection being used:*
Tank:
Piping: (TK # 3) - (Installing) partial Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> <p>Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108</p>	<p>Contact Person: Nate Meyer Phone: (815) 398-6250</p> <p>Contractor Registration # IL-1890 Exp. 03/07/2016</p>
--	---

Sincerely,

Jim Coffey