



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

## Amended

FOR OFFICE USE ONLY

Facility # 2-020577  
Permit # 00136-2014ABN  
Request Rec'd 02/18/2014  
**Amended Date 06/09/2014**  
Approval Date 2/20/2014 JC  
Permit Expires 8/20/2014

**Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Chase Products Company 2801 Gardner Road Broadview, IL 60153 Contact: Peter Chin	<b>(2) FACILITY</b> - name and address where tanks are located: Chase Products Company 2801 Gardner Road Broadview, Cook Co., IL Contact: Peter Chin (708) 865-1000
--	---

**(3) ABANDONMENT IN PLACE OF TANKS:**

- (a) *Number and size tanks being abandoned:* (TK # 6, 7, 8) - 6,000 gallons, **(TK # 14) - 8,300 gallons**, (TK # 18) - 10,000 gallons
- (b) *Product stored in each tank:* (TK # 6, 7, 8, **14**, 18) - Hazardous Substance (Heptane)
- (c) *Location of tanks being abandoned:* CONTAMINATED SITE! IEMA Number: 20140062
- (d) *Location of piping being abandoned:* **See contingencies section.**

- (4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.
- (5) **SPECIAL CONTINGENCIES:** Amendment request was received 06/09/14 to add tank #14 to this permit (the tank was originally going to be removed under permit #00133-2014REM). **Tank #14 and associated piping are in active tank and piping fields.** Fill material will be granular and / or flowable fill. Tank #18 is approximately 15' from the building; however, there are overhead utility / power wires tracking over the tank. Tanks 6, 7, 8 are close to the building, close to exterior propane pumping equipment, and inaccessible to heavy excavating equipment without damaging adjacent infrastructure. Conversation with Nick Cuzzone on 02/19/14 (Senior P.E. for EPS Environmental Services) confirms the tank locations. The piping for these tanks go straight into the building and will also be abandoned. Site assessment is on file.
- (6) The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

<b>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</b> Tsarpalas Enterprises, Inc. 17494 West Hickory Lane Grayslake, IL 60030	Contact Person: Steve A Tsarpalas Phone: (847) 816-8828 Contractor Registration # IL-297 Exp. 05/10/2014
--	--

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)