



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-021159  
Permit # 00534-2014UPG  
Request Rec'd 06/10/2014  
Amended Date  
Approval Date 6/10/2014 JC  
Permit Expires 12/10/2014

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Riteline Properties, LLC 200 W. Higgins Rd. Schaumburg, IL 60195 Contact: Robert Stambolic (847) 361-5927	<b>(2) FACILITY</b> - name and address where tanks are located: Shell Service Station 2501 Meacham Road Schaumburg, Cook Co., IL Contact: Harry Psarros (847) 922-6376
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 6, 7) - 15,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 6, 7) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX to replace all the existing product piping within the existing trench lines.
- (d) *Product to be stored in each tank:* (TK # 6, 7) - Gasoline
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:* (TK # 6, 7) - (Installing) Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES:** Section 175.410 and 175.420 apply to this permit regarding submersible sumps, dispenser sumps, and interstitial sump sensors. If these items are not already existing, they must be installed (this would require amending this permit to include said items). Also, see permit #00535-2014INS.

<b><u>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b> Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Hoyt Ary Phone: (708) 243-9081 Contractor Registration # IL-002275 Exp. 05/21/2016
--	--

Sincerely,

Jim Coffey

