



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 5-021667
Permit # 00573-2014UPG
Request Rec'd 06/17/2014
Amended Date
Approval Date 6/17/2014 DS
Permit Expires 12/17/2014

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Moto, Inc. 721 W. Main St., P.O. Box 122 Belleville, IL 62222-0122 Contact: Rob Whittington (618) 233-6754 Ext. 106	(2) FACILITY - name and address where tanks are located: Hillsboro Motomart 601 South Main & School Hwy 16 & 127 Hillsboro, Montgomery Co., IL Contact: Gail Phillips (217) 532-6651
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 4) - 10,000 gallons, (TK # 5) - 8,000 gallons, (TK # 6) - 6,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 4, 5, 6) - (Installing) Partial Fiberglass Single Wall Piping to accomodate new dispenser sumps, (TK # 4, 5, 6) - (Installing) Dispenser Sumps containment FRP
- (d) *Product to be stored in each tank:* (TK # 4, 5) - Gasoline, (TK # 6) - Diesel Fuel
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:* (TK # 4, 5, 6) - (Installing) Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: UPC Enterprises, LC d/b/a United Petroleum Service 1458 Collins Street St. Louis, MO 63102	Contact Person: Terry Smith Phone: (314) 241-3767 Contractor Registration # IL-002402 Exp. 02/10/2016
---	---

Sincerely,

Daniel Starks