



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

Permit for Emergency Repair Request on 06/23/2014

FOR OFFICE USE ONLY

Facility # 2-043724
Permit # 00613-2014UPG
Request Rec'd 07/01/2014
Amended Date
Approval Date 7/2/2014 JC
Permit Expires 7/17/2014

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Enterprise 1050 Lombard Rd. Lombard, IL 60148 Contact: Steve Dattilo (847) 928-3320	(2) FACILITY - name and address where tanks are located: Enterprise Rent-A-Car 4025 N. Mannheim Rd. Schiller Park, Cook Co., IL Contact: Tom Tremblay (708) 807-6244
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired:* (TK # 2) - 6,000 gallons
- (b) Type of tanks:*
- (c) Type of piping:* (TK # 2) - (Installing) bung adapter fitting at the tank sump to accommodate the repair of a leak found at the tank piping sump bung that was allowing water to leak into the tank.
- (d) Product to be stored in each tank:* (TK # 2) - Diesel Fuel
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:* (TK # 2) - (Installing) Manhole Pre-manufactured OPW Edge 1C-3112D spill containment manhole to replace the existing spill containment manhole.
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) SPECIAL CONTINGENCIES:** All emergency repairs require a permit applied for after the fact on the next business day and require a final inspection scheduled pursuant to section 175.320(d)(4) 10 days after issuance of the permit (see section 175.710(a)). The final inspection must be scheduled by 07/17/14.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Hoyt Ary Phone: (708) 243-9081 Contractor Registration # IL-002275 Exp. 05/21/2016
---	--

Sincerely,



Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)