



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

**Amended**

**FOR OFFICE USE ONLY**

Facility # 2-020578

Permit # 00563-2014UPG

Request Rec'd 06/17/2014

**Amended Date 07/10/2014**

Approval Date 6/17/2014 JC

Permit Expires 12/17/2014

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Provena Mercy Center 1325 N. Highland Avenue Aurora, IL 60506  Contact: Connie Nester (630) 801-5526	<b>(2) FACILITY</b> - name and address where tanks are located:  Provena Mercy Center Power Plant 1325 N. Highland Avenue Aurora, Kane Co., IL  Contact: Mike Molnar (630) 801-2659
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired:* (TK # 7) - 4,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 7) - (Installing) Transition Sump FRP fiberglass near the north corner of the building , (TK # 7) - (Installing) Fiberglass Double Wall Ameron supply and return lines to replace the existing supply and return lines.

(d) *Product to be stored in each tank:* (TK # 7) - Diesel Fuel

(e) *Type of leak detection being used:*

*Tank:*

*Piping:* (TK # 7) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at the transition sump only (the file and this permit application indicates this piping is a European suction system and there is an existing sump sensor at the tank sump).

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:* (TK # 7) - (Installing) Fiberglass Non-Corrosive

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** Amendment request received 07/10/14 to change the location of the transition sump to the north side as opposed to the south side per amended site plan. The original site plan was incorrect regarding where the original piping run was located. The amended site plan shows the original piping run; consequently showing the new replacement piping being installed in the same trench line, along with the transition sump location. The original permit was approved by Dan Starks.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  Metro Environmental Contractors, Inc. dba Metro Tank & Pump Company 1111 West Dundee Road Wheeling, IL 60090-3906	Contact Person: Larry Cherner Phone: (847) 465-4000  Contractor Registration # IL-102 Exp. 02/07/2016
--	--

Sincerely,

A handwritten signature in cursive script, reading "James J. Coffey", is written over a horizontal line.

Jim Coffey

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)