

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)785-1020

FOR OFFICE USE ONLY

Facility # 3-020603 Permit # 00669-2014CAT Request Rec'd 07/21/2014 Amended Date Approval Date 7/21/2014 DS Permit Expires 1/21/2015

Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Bloom Fuel, Inc. 502 Pratt Ave. North Schaumburg, IL 60193	Pekin Enterprise, Inc. 1201 Court Street Pekin, Tazewell Co., IL
Contact: Narain Gulabani (630) 235-7823	Contact: Jessica Stuart (309) 347-4656

(3) , UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:

- (a) Number and size of tanks having cathodic protection installed, upgraded, or repaired: (TK # 4, 5) 10,000 gallons
- (b) Type of tanks:
- (c) Type of piping:
- (d) Product to be stored in each tank: (TK # 4, 5) Gasoline
- (e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping: (TK # 4, 5) - (Installing) Sacrificial Anode Cathodic Protection in submersible sumps

(g) NACE certified designer:

- Certification number:
- (h) Method of integrity assessment of tank(s) being used:
- (4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES**:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Total Petroleum Service Company 2421 Washington Road Washington, IL 61571 Contact Person: Tom Oltman Phone: (309) 694-8224

Caniel J. Starke

Contractor Registration # IL-1079 Exp. 02/08/2016

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -Fire Department -Division File (Rev. - 9/10)