



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

FOR OFFICE USE ONLY
 Facility # 2-045640
 Permit # 00711-2014ABN
 Request Rec'd 07/31/2014
 Amended Date
 Approval Date 7/31/2014 JC
 Permit Expires 2/2/2015

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Lake Villa School District #41 131 McKinley Avenue Lake Villa, IL 60046 Contact: Al Alhakey</p>	<p>(2) FACILITY - name and address where tanks are located: Hooper Elementary School 2400 Sand Lake Road Lindenhurst, Lake Co., IL Contact:</p>
--	--

(3) ABANDONMENT IN PLACE OF TANKS:

- (a) *Number and size tanks being abandoned:* (TK # 1) - 1,000 gallons
- (b) *Product stored in each tank:* (TK # 1) - Heating Oil
- (c) *Location of tanks being abandoned:* **See contingencies section.**
- (d) *Location of piping being abandoned:* **See contingencies section.**

(4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.

(5) **SPECIAL CONTINGENCIES: Site assessment is on file showing clean site. Tank will be filled with low-strength concrete slurry mix. The tank is larger than anticipated (6000 gallons), and within 5' of the building and foundations. The east end of the tank was located approximately one foot from the east building, and the west end of the tank was located underneath the ComEd and Nicor underground utility services to the boiler room in the school.**

(6) The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

<p>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	
<p>RW Collins Company 7225 West 66th Street Chicago, IL 60638</p>	<p>Contact Person: Kim Collins Phone: (708) 458-6868 Contractor Registration # IL-772 Exp. 02/09/2016</p>

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
 Fire Department -
 Division File
 (Rev. - 9/10)