



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

## Extended

FOR OFFICE USE ONLY

Facility # 4-001845  
Permit # 00088-2014ABN  
Request Rec'd 01/31/2014  
Amended Date  
Approval Date 2/4/2014 JC  
**Permit Expires 2/4/2015**

**Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Shreeji Variety, Inc. 700 W. Oak Street Fairbury, IL 61739 Contact: Murda Patel (815) 692-3083	<b>(2) FACILITY</b> - name and address where tanks are located: Fairbury Shell 700 W. Oak St. Fairbury, Livingston Co., IL Contact: Murda Patel (815) 692-3083
--	--

**(3) ABANDONMENT IN PLACE OF TANKS:**

- (a) Number and size tanks being abandoned:* (TK # 1) - 6,000 gallons
- (b) Product stored in each tank:* (TK # 1) - Gasoline
- (c) Location of tanks being abandoned:* **See contingencies section and site plan.**
- (d) Location of piping being abandoned:* **See contingencies section and site plan.**

- (4)** This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.

- (5) SPECIAL CONTINGENCIES: Extension request was received 08/01/14. Fill material will be slurry mix. Tank and associated piping will be abandoned. Tank is located within an active tank field and the piping is located within the active piping trench. The tank lining is bad and did not pass inspection. Ste assessment is on file. Certificate of site condition indicates a clean site.**

- (6)** The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

<b>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b> Pemco Service Company, Inc. 1040 East Second Street Gilman, IL 60938	Contact Person: William "Butch" VonDrehle Phone: (815) 265-7364 Contractor Registration # IL-1224 Exp. 02/23/2014
--	---

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)