



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020

<u>FOR OFFICE USE ONLY</u>
Facility # 1-038981
Permit # 00714-2014UPG
Request Rec'd 08/04/2014
Amended Date
Approval Date 8/4/2014 JC
Permit Expires 2/4/2015

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          Pilot Travel Centers, LLC          5508 Lonas Rd.          Knoxville, TN 37909-3221          Contact: Joey Cupp (800) 562-6210 Ext. 2826</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Flying J Travel Plaza #644          343 Civic Road          La Salle, LaSalle Co., IL          Contact: Joey Cupp, Sr.</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 4) - 20,000 gallons, (TK # 5) - 12,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 4, 5) - (Installing) Shear Valves (total of two) at dispenser sump #16 to replace two existing shear valves only.
- (d) *Product to be stored in each tank:* (TK # 4, 5) - Gasoline
- (e) *Type of leak detection being used:*  
     *Tank:*  
     *Piping:*
- (f) *Corrosion Protection being used:*  
     *Tank:*  
     *Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

**(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Neumayer Equipment Company, Inc. 5060 Arsenal Street Saint Louis, MO 63139	Contact Person: Justin Burkemper Phone: (314) 772-4501 Contractor Registration # IL-1502 Exp. 03/26/2016

Sincerely,

Jim Coffey