



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-028249  
Permit # 00730-2014UPG  
Request Rec'd 08/06/2014  
Amended Date  
Approval Date 8/6/2014 DS  
Permit Expires 2/6/2015

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: City of Harvey Police Department 15301 Dixie Highway Harvey, IL 60426 Contact: Steve Jospheon (708) 210-5404	<b>(2) FACILITY</b> - name and address where tanks are located: City of Harvey Police Department 15301 Dixie Highway Harvey, Cook Co., IL Contact: Steve Jospheon (708) 210-5404
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1) - (Installing) Dispenser Sumps containment FRP, (TK # 1) - (Installing) Tank Sump containment FRP, (TK # 1) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX from existing tank to new dispenser
- (d) *Product to be stored in each tank:* (TK # 1) - Gasoline
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:* (TK # 1) - (Installing) European with No Test Req Suction
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:* (TK # 1) - (Installing) Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b> Petroleum Technologies Equipment, Inc. 8447 West 44th Place Lyons, IL 60534	Contact Person: Thomas J JR Doherty Phone: (708) 579-9189 Ext. Contractor Registration # IL-2051 Exp. 01/17/2016
--	--

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)