



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

**FOR OFFICE USE ONLY**

Facility # 2-000503  
Permit # 00753-2014UPG  
Request Rec'd 08/13/2014  
Amended Date  
Approval Date 8/13/2014 DS  
Permit Expires 2/13/2015

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Village of Elk Grove Village 901 Wellington Avenue Elk Grove Village, IL 60007 Contact: Dave Preissig (847) 734-8046	<b>(2) FACILITY</b> - name and address where tanks are located: Village of Elk Grove Village 666 Landmeier Road Elk Grove Village, Cook Co., IL Contact: Dave Preissig (847) 734-8081
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 8,000 gallons, (TK # 11, 12) - 4,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank:* (TK # 1, 12) - Gasoline, (TK # 11) - Diesel Fuel

(e) *Type of leak detection being used:*

*Tank:* (TK # 1, 11, 12) - (Installing) Automatic Tank Gauging Omntec OEL 8000 II with printer and probes

*Piping:*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b> Accurate Tank Technologies, Inc. 204 Poplar Place North Aurora, IL 60542	Contact Person: Jason Reed Phone: (630) 375-6121 Ext. 10 Contractor Registration # IL-1594 Exp. 02/23/2016
---	--

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)