



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

FOR OFFICE USE ONLY

Facility # 4-016960  
Permit # 00818-2014INS  
Request Rec'd 09/02/2014  
Amended Date  
Approval Date 9/2/2014 JC  
Permit Expires 3/2/2015

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Food 4 Less 1100 W. Artesia Blvd. Compton, CA 90220  Contact: Charles Cousar (815) 274-4766	<b>(2) FACILITY</b> - name and address where tanks are located:  Food 4 Less 855 N. Fairview Decatur, Macon Co., IL  Contact: Smoller, Ronald K. (918) 661-6600
--	---

**(3) INSTALLATION OF TANKS:**

- (a) Number and size of tanks being installed:** (TK # 6) - 20,000 gallons, and one compartment tank consisting of the following two: (TK # 7) - 10,000 gallons, (TK # 8) - 8,000 gallons
- (b) Type of tanks:** (TK # 6, 7, 8) - (Installing) Fiberglass Brine Filled Double Wall XERXES
- (c) Type of piping:** (TK # 6, 7, 8) - (Installing) Flexible Double Wall OPW Flexworks CP-15 non corrosive
- (d) Product to be stored in each tank:** (TK # 6, 8) - Gasoline, (TK # 7) - Diesel Fuel
- (e) Type of leak detection being used:**
  - Tank:** (TK # 6, 7, 8) - (Installing) Hydrostatic Reservoir Sensors Interstitial Monitoring Veeder Root TLS 450 Plus Interstitial tank sensor, (TK # 6, 7, 8) - (Installing) Automatic Tank Gauging Veeder Root TLS 450 Plus ATG leak detection and inventory control.
  - Piping:** (TK # 6, 7, 8) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 450 Plus at all submersible sumps and at all dispenser sumps, (TK # 6, 7, 8) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 450 Plus
- (f) Corrosion Protection being used:**
  - Tank:** (TK # 6, 7, 8) - (Installing) Fiberglass Non-Corrosive
  - Piping:** (TK # 6, 7, 8) - (Installing) Flexible Non-Corrosive
- (g) Spill containment devices, piping and dispenser containment devices:** (TK # 6, 7, 8) - (Installing) Manhole Pre-manufactured Franklin Fueling Systems DMP 36-2-SW 36" multi-port
- (h) Overfill prevention devices:** (TK # 6, 7, 8) - (Installing) Ball Float Vent Valve OPW 53VML

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**

- (5) GENERAL REQUIREMENTS:** There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

**(6) SPECIAL CONTINGENCIES:**

<b>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Hoyt Ary Phone: (708) 243-9081  Contractor Registration # IL-002275 Exp. 05/21/2016
---	--

Sincerely,

A handwritten signature in dark ink, reading "James J. Coffey", is written over a horizontal line.

Jim Coffey

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)