



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

FOR OFFICE USE ONLY

Facility # 6-000699  
Permit # 00814-2014UPG  
Request Rec'd 09/02/2014  
Amended Date  
Approval Date 9/2/2014 JC  
Permit Expires 3/2/2015

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Little Nashville, Inc. 11700 State Route 127, P.O. Box 243 Nashville, IL 62263 Contact: Thomas Gray (618) 478-5777	<b>(2) FACILITY</b> - name and address where tanks are located: Little Nashville, Inc. 11700 State Route 127, P.O. Box 243 Nashville, Washington Co., IL Contact: Thomas Gray (618) 478-5777
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 5, 6, 7) - 10,000 gallons, (TK # 8) - 4,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 5, 6, 7, 8) - (Installing) partial Fiberglass Single Wall Piping to accommodate new sumps, and to accommodate adjusting shear valves to proper height under dispenser #5/6, and master dispenser #9 and #10 only, (TK # 5, 6, 7, 8) - (Installing) Dispenser Sumps containment FRP under dispenser #5/6, and under master dispenser #9 and #10 only, (TK # 5, 6, 7, 8) - (Installing) Flex Connector Steel under dispenser #5/6, and master dispenser #9 and #10 only, (TK # 5, 6, 7, 8) - (Installing) Shear Valves at dispenser #5/6, and master dispenser #9 and #10 only.
- (d) *Product to be stored in each tank:* (TK # 5, 8) - Gasoline, (TK # 6, 7) - Diesel Fuel
- (e) *Type of leak detection being used:*  
*Tank:*  
*Piping:*
- (f) *Corrosion Protection being used:*  
*Tank:*  
*Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b> UPC Enterprises, LC d/b/a United Petroleum Service 1458 Collins Street St. Louis, MO 63102	Contact Person: Harvey Stokes Phone: (314) 241-3767 Contractor Registration # IL-002402 Exp. 02/10/2016
---	---

Sincerely,

Jim Coffey

