



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-031976  
Permit # 00817-2014UPG  
Request Rec'd 09/02/2014  
Amended Date  
Approval Date 9/2/2014 JC  
Permit Expires 3/2/2015

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: PACE Suburban Bus 550 West Algonquin Road Arlington Heights, IL 60005 Contact: Dave Szaflarski (847) 228-4228	<b>(2) FACILITY</b> - name and address where tanks are located: Pace North Shore Facility 2330 Oakton Street Evanston, Cook Co., IL Contact: Larry Sitkiewicz (847) 869-3278
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired:* (TK # 1, 2) - 20,000 gallons, (TK # 4) - 2,500 gallons, (TK # 5) - 1,000 gallons
  - (b) Type of tanks:*
  - (c) Type of piping:* (TK # 1, 2) - (Installing) Flex Connector Steel at the two diesel dispensers only, (TK # 1, 2) - (Installing) Shear Valves at the two diesel dispensers only, (TK # 1, 2) - (Installing) Dispenser Sumps containment FRP for the two diesel dispensers only (also replacing dispenser tops), (TK # 1) - (Installing) submersible pump to replace the existing pump, (TK # 4, 5) - (Installing) Transition / tank Sumps FRP fiberglass sump reducers (**see site plan and contingencies section for explanation of further work being done**).
  - (d) Product to be stored in each tank:* (TK # 1, 2) - Diesel Fuel, (TK # 4) - New Oil, (TK # 5) - Automatic Transmission Fluid
  - (e) Type of leak detection being used:*
    - Tank:*
    - Piping:* (TK # 1, 2) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at the two diesel dispensers only, (TK # 1) - (Installing) Mechanical Pressurized Line Leak Detection Red Jacket FX1DV
  - (f) Corrosion Protection being used:*
    - Tank:*
    - Piping:*
  - (g) Spill containment devices, piping, and dispenser containment devices:*
  - (h) Overfill prevention devices:*
  - (i) Manway accessible at grade:*
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES:** Contractor is also going to remove and replace two manhole lids / manhole frames for tank #3. Further, the contractor is replacing all access manhole lids / manhole frames for all existing ancillary tank top equipment for tanks 4 and 5, and will also include adding two new tank sump reducers to the existing tank sumps for tanks 4 and 5.

<b><u>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b> Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Marc Bourgault Phone: (815) 398-6250 Contractor Registration # IL-1890 Exp. 03/07/2016
--	--

Sincerely,

A handwritten signature in cursive script, reading "Jim Coffey", is written over a horizontal line.

Jim Coffey

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)