



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020
Extended

FOR OFFICE USE ONLY
Facility # 4-008000
Permit # 00202-2014REM
Request Rec'd 03/13/2014
Amended Date
Approval Date 3/13/2014 DS
Permit Expires 3/15/2015

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Wortman-Meyer Properties, LLC P.O. Box 217, Effingham, IL 62401 Contact: Lisa Wortman (217) 342-7291	(2) FACILITY - name and address where tanks are located: Jack Flash 1200 North Keller Drive, Keller Dr. & I-57 Effingham, Effingham Co., IL Contact: Gail Bushue (217) 347-5322
--	--

(3) REMOVAL OF TANKS:

- (a) Number and size of tanks being removed:* (TK # 9) - 15,000 gallons, (TK # 10, 11) - 8,000 gallons
- (b) Description/location of piping being removed:*
- (c) Product stored in each tank:* (TK # 9, 10) - Gasoline, (TK # 11) - Diesel Fuel
- (d) Reason of tanks being removed:*
- (e) If tank(s) is leaking, indicate IEMA incident number:*
- (f) Date each tank was last used:* (TK # 9), (TK # 10), (TK # 11)

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.**

- (5) SPECIAL CONTINGENCIES:** This permit is for piping removal only. All of the product piping will be removed, some of the chase duct piping will be removed and some of the existing chase duct piping will remain existing to be re-used with portions of new supply product piping running through them as necessary to accommodate the addition of new islands. The existing tanks will remain. See permit #00203-2014UPG for further information regarding this job.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: UPC Enterprises, LC d/b/a United Petroleum Service 1458 Collins Street St. Louis, MO 63102	Contact Person: Harvey Stokes Phone: (314) 241-3767 Contractor Registration # IL-002402 Exp. 02/10/2016
---	---

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)