



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020  
**Extended**

<b>FOR OFFICE USE ONLY</b>
Facility # 4-008000
Permit # 00203-2014UPG
Request Rec'd 03/13/2014
Amended Date
Approval Date 3/14/2014 DS
Permit Expires 3/15/2015

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overflow prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          Wortman-Meyer Properties, LLC          P.O. Box 217,          Effingham, IL 62401          Contact: Lisa Wortman (217) 342-7291</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Jack Flash          1200 North Keller Drive, Keller Dr. &amp; I-57          Effingham, Effingham Co., IL          Contact: Gail Bushue (217) 347-5322</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**


- (a) **Number and size of tanks being upgraded or repaired:** (TK # 9) - 15,000 gallons, (TK # 10, 11) - 8,000 gallons
- (b) **Type of tanks:**
- (c) **Type of piping:** (TK # 9, 10, 11) - (Installing) Dispenser Sumps containment FRP (total of 10 islands), (TK # 9, 10, 11) - (Installing) Flexible Double Wall A.P.T. Poly Tech P200SC primary product piping from each submersible to each of the ten islands - this will accommodate the addition of four new islands and the re-piping of six of the existing islands, (TK # 9, 10, 11) - (Installing) Chase Secondary Containment OPW AXP - 4" secondary chase piping as necessary to accommodate installation of the new islands and re-piping of existing islands ( new chase piping will hook into some of the existing chase piping), (TK # 9) - (Installing) Submersible Sumps containment FRP
- (d) **Product to be stored in each tank:** (TK # 9, 10) - Gasoline, (TK # 11) - Diesel Fuel
- (e) **Type of leak detection being used:**  
  - Tank:** (TK # 9, 10, 11) - (Installing) Automatic Tank Gauging Veeder Root TLS 350 Plus console only. The existing probes to remain
  - Piping:** (TK # 9, 10, 11) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 Plus at all dispenser island sumps and at the submersible sump for tank #9 only.
- (f) **Corrosion Protection being used:**  
  - Tank:**
  - Piping:** (TK # 9, 10, 11) - (Installing) Flexible Non-Corrosive , (TK # 9, 10, 11) - (Installing) Fiberglass Non-Corrosive
- (g) **Spill containment devices, piping, and dispenser containment devices:**
- (h) **Overflow prevention devices:**
- (i) **Manway accessible at grade:**

**(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overflow prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:** See permit #00202-2014REM for further information regarding this job.

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>          UPC Enterprises, LC d/b/a United Petroleum Service          1458 Collins Street          St. Louis, MO 63102</p>	<p>Contact Person: Harvey Stokes          Phone: (314) 241-3767          Contractor Registration # IL-002402 Exp. 02/10/2016</p>
--	--

Sincerely,

  
\_\_\_\_\_

Daniel Starks

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)