



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

<p align="center"><u>FOR OFFICE USE ONLY</u></p> <p>Facility # 2-012592 Permit # 00751-2014UPG Request Rec'd 08/13/2014 Amended Date 09/15/2014 Approval Date 9/3/2014 JC Permit Expires 3/3/2015</p>

Amended

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Singh Inc of Il 43067 N Hwy 41 Wadsworth, IL 60083 Contact: "Sam" Surjit Toor (414) 234-0133</p>	<p>(2) FACILITY - name and address where tanks are located: Toor's Car & Truck Plaza 43067 N. Hwy. 41,I-94 & Russell Rd. Wadsworth, Lake Co., IL Contact: Mark Toor (847) 395-5000</p>
-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 10) - 8,000 gallons, (TK # 12) - 20,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 10, 12) - (Installing) Dispenser Sumps containment FRP at the new eastern - most truck island satellite dispenser only., (TK # 10, 12) - (Installing) partial Fiberglass Double Wall A.O. Smith between the submersible pumps for tanks 10 and 12 (this will be manifold piping to accommodate the conversion of tank #10 from mid-grade to diesel). This will also effectively allow the existing mid-grade piping to the three existing auto lane dispensers become diesel supply from tanks 10 and 12. There will also be a new run of piping from the existing eastern - most diesel truck island dispenser to supply the new eastern - most truck island satellite dispenser.
- (d) *Product to be stored in each tank:* (TK # 10) - Gasoline, (TK # 12) - Diesel Fuel
- (e) *Type of leak detection being used:*
Tank:
Piping: (TK # 10, 12) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root EMC at the submersible sumps for tanks 10 and 12, and at the existing eastern most diesel truck island dispenser, and at the new satellite dispenser only.
- (f) *Corrosion Protection being used:*
Tank:
Piping: (TK # 10, 12) - (Installing) Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES: This permit is being amended to delete the proposal to convert tank #10 DEF as originally proposed. Tank #10 will now be converted to diesel instead. Furthermore, the only piping to be installed will be between the submersible pumps of tank #10 and #12 (manifold piping), and new piping from the existing easternmost dispenser to the new east satellite dispenser. Sensors will only be installed in the new satellite dispenser sump, the existing easternmost dispenser sump, and at the submersible sumps for tanks 10 and 12. Refer to this original permit and site plan to see the full history of this approved permit under this configuration.

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>

Walts Petroleum Service Inc.
5207 E. Jelenik Ave., Autank
Schofield, WI 54476

Contact Person: Paul Kilde
Phone: (715) 359-4362

Contractor Registration # IL-1951 Exp. 04/10/2016

Sincerely,

A handwritten signature in cursive script, reading "James J. Coffey", is written over a solid horizontal line.

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)