



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020
Amended

FOR OFFICE USE ONLY

Facility # 2-014561
Permit # 00597-2014UPG
Request Rec'd 06/26/2014
Amended Date 09/23/2014
Approval Date 6/26/2014 DS
Permit Expires 12/26/2014

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Speedway, LLC P.O. Box 1500 Springfield, OH 45501-1500 Contact: Toby Rickabaugh (937) 863-7034	(2) FACILITY - name and address where tanks are located: Speedway #7427 7201 West 183rd Street Tinley Park, Cook Co., IL Contact: John Helms (937) 863-6508
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 2, 3, 4, 5) - 10,000 gallons, (TK # 6) - 4,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 1, 2, 3, 4, 5, 6) - (Installing) Dispenser Sumps containment FRP, (TK # 1, 2, 3, 4, 5, 6) - (Installing) Submersible Sumps containment FRP, (TK # 2, 3, 4) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX across tanks 2, 3, & 4 as a syphon bar. Tanks #3 & 4 will have submersible pumps, (TK # 6) - (Installing) Flexible Double Wall A.P.T. Poly Tech P175SC for E-85 dispensing to two existing dispensers

(d) *Product to be stored in each tank:* (TK # 1, 2, 3, 4) - Gasoline, (TK # 5) - Diesel Fuel, (TK # 6) - Kerosene

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 1, 2, 3, 4, 5, 6) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 450 at all submersible and dispenser sumps

(f) *Corrosion Protection being used:*

Tank:

Piping: (TK # 6) - (Installing) Flexible Non-Corrosive

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** See permit #01199-2013UPG (expired 06/02/14) for further information regarding this new permit. Contractor requests 2 separate inspections for this permit work. See also 175.820(b) concerning tank #6. The underground storage tank system for tank #6 must be compatible with E-85, as indicated in section 175.415 of Title 41 of the Illinois Administrative Code, and as indicated in the U.S. EPA Federal Register vol.76, no.128, July 5th 2011 notices regarding the storage and dispensing of alternative fuels. Permit amended on 9/23/14 to show the installation of a syphon bar installed across tanks 2, 3, & 4

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: W. G. Gentry Company, Inc. 3150 S. 460 E. La Fayette, IN 47905	Contact Person: Jon Mill Phone: (765) 742-4001 Contractor Registration # IL-002262 Exp. 10/10/2014
---	--

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)