



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

Permit for Emergency Repair Request on 09/22/2014

FOR OFFICE USE ONLY

Facility # 4-014519
Permit # 00902-2014UPG
Request Rec'd 09/23/2014
Amended Date
Approval Date 9/23/2014 DS
Permit Expires 10/7/2014

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity:

Mac's Convenience Stores, LLC
4080 W. Johnson Moore Pike,
Columbus, IN 42701-0347

Contact: Matthew Jordan (812) 379-9227

(2) FACILITY - name and address where tanks are located:

Circle K #1305
2606 North Vermilion Street
Danville, Vermilion Co., IL

Contact: Jennifer Houseman (217) 442-8245

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired:* (TK # 5, 6, 7) - 10,000 gallons, (TK # 8) - 4,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank:* (TK # 5, 6, 7) - Gasoline, (TK # 8) - Diesel Fuel

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 5, 6, 7) - (Installing) Mechanical Pressurized Line Leak Detection FE Petro STP-MLD, (TK # 8) - (Installing) Mechanical Pressurized Line Leak Detection FE Petro STP-MLD-D

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
Saint Louis, MO 63139

Contact Person: Rick McKay
Phone: (314) 772-4501

Contractor Registration # IL-1502 Exp. 03/26/2016

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)