



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 5-027648
Permit # 00941-2014UPG
Request Rec'd 10/03/2014
Amended Date
Approval Date 10/3/2014 JC
Permit Expires 4/3/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Casey's Retail Company One Convenience Blvd., P.O. Box 3001 Ankeny, IA 50021 Contact: Jill Reams-Widder (515) 965-6238	(2) FACILITY - name and address where tanks are located: Casey's General Store #2939 3001 East Clear Lake Avenue Springfield, Sangamon Co., IL Contact: Jill Reams Widder (515) 965-6238
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 6, 7) - 10,000 gallons, (TK # 8, 9) - 5,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 6, 7, 8, 9) - (Installing) Dispenser Sumps containment FRP at dispenser #1/2, #3/4, and at the kerosene dispenser only (these dispensers are at the far east end of the island clusters, (TK # 8) - (Installing) Submersible Sump containment FRP. The contractor will also be installing new fittings on existing flexible product piping to accommodate the new sumps.
- (d) *Product to be stored in each tank:* (TK # 6, 7) - Gasoline, (TK # 8) - Diesel Fuel, (TK # 9) - Kerosene
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:* (TK # 8) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350R at the submersible sump only, (TK # 8) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350R
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES:** From old site plans it appears there is a siphon bar between tanks 3 & 4, and a siphon bar between tanks 1 and 2. Product piping from tank #3 is running to the sump at tank #8. Product piping from tank #1 is running to the sump at tank #7 (see site plan from permits 02153-2000UPG and 01652-2000UPG for tank and piping layout for this site).

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Seneca Companies, Inc. 458 N. Highway 48 Oreana, IL 62554	Contact Person: Chuck Hoenig Phone: (217) 468-2393 Contractor Registration # IL-598 Exp. 02/23/2016
--	---

Sincerely,



Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)