



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

<u>FOR OFFICE USE ONLY</u>
Facility # 7-021611
Permit # 00763-2014UPG
Request Rec'd 08/19/2014
Amended Date
Approval Date 8/19/2014 DS
Permit Expires 2/19/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Knapp Oil Company, Inc. 220 Front St., P.O. Box 215 Xenia, IL 62899</p> <p>Contact: Rick Forth (618) 678-2211</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Knapp Mart Albion 105 East Elm Street Albion, Edwards Co., IL</p> <p>Contact: Deena Downs (618) 445-3831</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 4) - 8,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 4) - (Installing) Dispenser Sumps containment FRP, (TK # 4) - (Installing) Submersible Sumps containment FRP, (TK # 4) - (Installing) Flexible Double Wall A.P.T. Poly Tech P150SC from existing tank to dispenser
- (d) *Product to be stored in each tank:* (TK # 4) - Gasoline
- (e) *Type of leak detection being used:*
 - Tank:* (TK # 4) - (Installing) Automatic Tank Gauging Veeder Root TLS 450 **PROBE**
 - Piping:* (TK # 4) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 450 in submersible and dispenser sump
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:* (TK # 4) - (Installing) Flexible Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES: Original permit had wrong tank listed

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Robert Ellis & Sons 1703 North 7th Street Murphysboro, IL 62966</p>	<p>Contact Person: Robert Ellis Phone: (618) 713-0765</p> <p>Contractor Registration # IL-980 Exp. 03/23/2016</p>

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -
 Fire Department -
 Division File
 (Rev. - 9/10)