



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020

<p align="center"><u>FOR OFFICE USE ONLY</u></p> <p>Facility # 2-045725          Permit # 00962-2014ABN          Request Rec'd 10/08/2014          Amended Date          Approval Date 10/9/2014 DS          Permit Expires 4/9/2015</p>
--

**Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Northwest Highway Building Partnership          2720 S River Rd          Des Plaines, IL 60018</p> <p>Contact:</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Northwest Highway Building Partnership          141-143 N Northwest Highway          Park Ridge, Cook Co., IL</p> <p>Contact:</p>
--	---

**(3) ABANDONMENT IN PLACE OF TANKS:**

- (a) Number and size tanks being abandoned:* (TK # 1) - 2,000 gallons
- (b) Product stored in each tank:* (TK # 1) - Heating Oil
- (c) Location of tanks being abandoned:* Tank is located in close proximity to an existing building as indicated in site plan. Attempting to remove the tank would undermine the structural integrity of the building.
- (d) Location of piping being abandoned:* ***Piping is located in close proximity to an existing building as indicated in site plan. Attempting to remove the piping would undermine the structural integrity of the building.***

**(4)** This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.

**(5) SPECIAL CONTINGENCIES:**

**(6)** The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

<p><b>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b></p> <p>Robinette Demolition, Inc.          O South 560 Highway 83          Oakbrook Terrace, IL 60181</p>	<p>Contact Person: Michael Leyden          Phone: (630) 883-7997</p> <p>Contractor Registration # IL-512 Exp. 08/14/2016</p>
---	--

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Division File  
 (Rev. - 9/10)