



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-022681
Permit # 00998-2014UPG
Request Rec'd 10/17/2014
Amended Date
Approval Date 10/17/2014 JC
Permit Expires 4/17/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Commonwealth Edison/Exelon Corporation 3 Lincoln Center - Real Estate & Facilities, Oakbrook Terrace, IL 60181-4260 Contact: Chuck Strong (219) 733-3417	(2) FACILITY - name and address where tanks are located: Crystal Lake District Headquarters 5100 South Route 31 Crystal Lake, McHenry Co., IL Contact: Renee Mazariegos (815) 447-5277
--	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired:* (TK # 3, 4) - 10,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 3, 4) - (Installing) Dispenser Sumps containment FRP at both dispensers, (TK # 3, 4) - (Installing) Flexible Double Wall OPW Flexworks CP-15 non corrosive to replace all existing piping, (TK # 3, 4) - (Installing) Submersible Sumps containment FRP

(d) *Product to be stored in each tank:* (TK # 3) - Gasoline, (TK # 4) - Diesel Fuel

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 3, 4) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at the two dispenser sumps only. There are existing sensors for the submersible sumps.

(f) *Corrosion Protection being used:*

Tank:

Piping: (TK # 3, 4) - (Installing) Flexible Non-Corrosive

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Superior Petroleum Marketers, Inc. 2336 Albright Lane , P. O.Box 4648 Wheaton, IL 60189-4648	Contact Person: Steve Tuttle Phone: (630) 588-1198 Contractor Registration # IL-2087 Exp. 02/04/2016
---	--

Sincerely,

Jim Coffey

