



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY

Facility # 2-014582
Permit # 01022-2014UPG
Request Rec'd 10/22/2014
Amended Date
Approval Date 10/22/2014 JC
Permit Expires 4/22/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Speedway, LLC P.O. Box 1500 Springfield, OH 45501-1500 Contact: Toby Rickabaugh (937) 863-7034	(2) FACILITY - name and address where tanks are located: Speedway #7568 499 W. Boughton Bolingbrook, Will Co., IL Contact: Dave Nycz (630) 759-1950
--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 13) - 4,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 13) - (Installing) Dispenser Sump containment FRP at the second closest dispenser to the tank field only, (TK # 13) - (Installing) Submersible Sump containment FRP, (TK # 13) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX from the submersible to the second closest dispenser to the tank field only.
- (d) *Product to be stored in each tank:* (TK # 13) - Kerosene
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:* (TK # 13) - (Installing) Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:* (TK # 13) - (Installing) Manhole Pre-manufactured OPW 1C-2100C-DEVVR
- (h) *Overfill prevention devices:* (TK # 13) - (Installing) Overfill Drop Tube Valve OPW 61SO
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES:** Facility is converting tank #13 from kerosene to E-85. The underground storage tank system for tank #13 must be compatible with E-85, as indicated in section 175.415 of Title 41 of the Illinois Administrative Code, and as indicated in the U.S. EPA Federal Register vol.76, no. 128, July 5th 2011 notices regarding the storage and dispensing of alternative fuels. Contractor states there is an existing line leak detector and existing sensors at the second closest dispenser to the tank field, and at the submersible.

<u>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Nate Meyer Phone: (815) 398-6250 Contractor Registration # IL-1890 Exp. 03/07/2016
----------------------------------------------------------------------------------------------------------------------------------------------	----------------------------------------------------------------------------------------------------------

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)