



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

FOR OFFICE USE ONLY

Facility # 6-021253  
Permit # 01047-2014UPG  
Request Rec'd 10/28/2014  
Amended Date  
Approval Date 10/28/2014 DS  
Permit Expires 4/28/2015

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: C C Dillon Company 1342 Lonedell Road Arnold, MO 63010 Contact: Gene Wagstaff (314) 296-2700	<b>(2) FACILITY</b> - name and address where tanks are located: Race Way Gas & Food 8407 Collinsville Road Collinsville, Madison Co., IL Contact: Nick Badwan (618) 344-8197
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired:* (TK # 1, 2) - 12,000 gallons, (TK # 3) - 6,000 gallons
- (b) Type of tanks:*
- (c) Type of piping:* (TK # 1, 2, 3) - (Installing) Partial Fiberglass Single Wall Piping Ameron (approximately 12') to accomodate moving the two Western most dispensers, (TK # 1, 2, 3) - (Installing) Dispenser Sumps containment FRP under all four dispensers.
- (d) Product to be stored in each tank:* (TK # 1, 2) - Gasoline, (TK # 3) - Racing Fuel
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:* (TK # 1, 2, 3) - (Installing) Fiberglass Non-Corrosive
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b> UPC Enterprises, LC d/b/a United Petroleum Service 1458 Collins Street St. Louis, MO 63102	Contact Person: Terry Smith Phone: (314) 241-3767 Contractor Registration # IL-002402 Exp. 02/10/2016
---	---

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)