



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

**FOR OFFICE USE ONLY**

Facility # 2-012333  
Permit # 01118-2014UPG  
Request Rec'd 11/19/2014  
Amended Date  
Approval Date 11/19/2014 DS  
Permit Expires 5/19/2015

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Du Page County 421 N. County Farm Rd. Wheaton, IL 60187 Contact: Scott Otterman (630) 407-5730	<b>(2) FACILITY</b> - name and address where tanks are located: Du Page County 200 N. County Farm Rd. Wheaton, Du Page Co., IL Contact: Chuck Curcio (630) 407-6931
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**


- (a) Number and size of tanks being upgraded or repaired:* (TK # 1, 2) - 10,000 gallons, (TK # 4) - 12,000 gallons
- (b) Type of tanks:*
- (c) Type of piping:* (TK # 1, 2, 4) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX from tanks to new dispenser islands, (TK # 1, 2, 4) - (Installing) Fiberglass Single Wall Vent Piping Ameron, (TK # 1, 2, 4) - (Installing) Submersible Sumps containment FRP, (TK # 1, 2, 4) - (Installing) Dispenser Sumps containment FRP
- (d) Product to be stored in each tank:* (TK # 1, 2) - Gasoline, (TK # 4) - Diesel Fuel
- (e) Type of leak detection being used:*
  - Tank:* Installing new VR tank probes to existing TLS350 ATG
  - Piping:* (TK # 1, 2, 4) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in all submersible and dispenser sumps, (TK # 1, 2, 4) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:* (TK # 1, 2, 4) - (Installing) Fiberglass Non-Corrosive
- (g) Spill containment devices, piping, and dispenser containment devices:* (TK # 1, 2, 4) - (Installing) Manhole Pre-manufactured EBW 715
- (h) Overfill prevention devices:* (TK # 1, 2) - (Installing) Overfill Drop Tube Valve OPW 61SOC, (TK # 4) - (Installing) Overfill Drop Tube Valve OPW 71SO
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b> Crowne Industries, Ltd. 2511 West Schaumburg Road, #358 Schaumburg, IL 60194	Contact Person: Robert Sumoski Phone: (630) 497-9009 Contractor Registration # IL-002345 Exp. 05/16/2016
---	--

Sincerely,



---

Daniel Starks

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)