



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY
Facility # 2-024337
Permit # 01140-2014INS
Request Rec'd 11/26/2014
Amended Date
Approval Date 11/26/2014 DS
Permit Expires 5/26/2015

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: JTL Group, Inc. 557 N. 3rd Street Des Plaines, IL 60016 Contact: Thomas Kuruvilla, R A</p>	<p>(2) FACILITY - name and address where tanks are located: South Harlem, Inc. 11458 S. Harlem Avenue Worth, Cook Co., IL Contact: Thomas Kuruvilla</p>
---	--

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed:* (TK # 5, 6) - 4,000 gallons, (TK # 7, 9) - 5,000 gallons
- (b) Type of tanks:* (TK # 5, 6) - (Installing) Fiberglass Double Wall Containment Solutions , (TK # 7, 9) - (Installing) Fiberglass Brine Filled Double Wall Containment Solutions
- (c) Type of piping:* (TK # 5, 6, 7, 9) - (Installing) Dispenser Sumps containment FRP, (TK # 5, 6, 7, 9) - (Installing) Submersible Sumps containment FRP, (TK # 5, 6, 7, 9) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX
- (d) Product to be stored in each tank:* (TK # 5) - Diesel Fuel, (TK # 6, 7, 9) - Gasoline
- (e) Type of leak detection being used:*
 - Tank:** (TK # 5, 6, 7, 9) - (Installing) Automatic Tank Gauging OPW Site Sentinel i Site , (TK # 5, 6, 7, 9) - (Installing) Interstitial Monitoring OPW Site Sentinel I-Site
 - Piping:** (TK # 5) - (Installing) Mechanical Pressurized Line Leak Detection FE Petro STP-MLD-D, (TK # 5, 6, 7, 9) - (Installing) Piping Sump Sensors Interstitial Monitoring OPW Site Sentinel I-Site in all submersible and dispenser sumps , (TK # 6, 7, 9) - (Installing) Mechanical Pressurized Line Leak Detection FE Petro STP-MLD
- (f) Corrosion Protection being used:*
 - Tank:** (TK # 5, 6, 7, 9) - (Installing) Fiberglass Non-Corrosive
 - Piping:** (TK # 5, 6, 7, 9) - (Installing) Fiberglass Non-Corrosive
- (g) Spill containment devices, piping and dispenser containment devices:* (TK # 5, 6, 7, 9) - (Installing) Manhole Pre-manufactured EBW 705
- (h) Overfill prevention devices:* (TK # 5) - (Installing) Overfill Drop Tube Valve OPW 61SOC , (TK # 6, 7, 9) - (Installing) Overfill Drop Tube Valve OPW 71SO

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) GENERAL REQUIREMENTS: There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) SPECIAL CONTINGENCIES: This permit replaces previous permit #01227-2013 which had been amended once already. The only change to permit is from OPW EECO 1500 tank gauging and line leak detection to OPW i-site


(7) PERSON, FIRM OR COMPANY PERFORMING WORK:

Metro Environmental Contractors, Inc. dba Metro Tank & Pump
Company
1111 West Dundee Road
Wheeling, IL 60090-3906

Contact Person: Larry Cherner
Phone: (847) 465-4000

Contractor Registration # IL-102 Exp. 02/07/2016

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)