



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY
Facility # 3-024855
Permit # 01152-2014UPG
Request Rec'd 12/01/2014
Amended Date
Approval Date 12/1/2014 JC
Permit Expires 12/15/2014

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Broadway Gas, Inc. 1401 Broadway Pekin, IL 61554 Contact: Archita Reddy (309) 453-4450	(2) FACILITY - name and address where tanks are located: Broadway Gas, Inc. 1401 Broadway Pekin, Tazewell Co., IL Contact: Ashraf Sayeed (630) 205-6372
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired:* (TK # 3) - 10,000 gallons
- (b) Type of tanks:*
- (c) Type of piping:* (TK # 3) - (Installing) partial Fiberglass Single Wall Piping (approximately two feet) to repair a short damaged section of existing piping.
- (d) Product to be stored in each tank:* (TK # 3) - Gasoline
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES:** Inspector note: this work has already been done through an emergency repair request and permit #01005-2014UPG; however, the follow up permit application to the emergency repair was not received until a later date; consequently, there were also scheduling issues that did not follow the proper criteria for emergency repairs. Permit #01152-2014UPG is therefore being issued as a result, and as a replacement of permit #01005-2014UPG to accommodate the final inspection process. All emergency repairs require a permit applied for after the fact on the next business day and require a final inspection scheduled pursuant to section 175.320(d)(4) 10 days after issuance of the permit (see section 175.710(a)). The final inspection must be scheduled by 12/15/14.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Tank Tech, Inc. 3975 State Highway H Sikeston, MO 63801	Contact Person: Rob Russell Phone: (573) 471-1932 Contractor Registration # IL-2136 Exp. 01/14/2016
--	---

Sincerely,



Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)