



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020

<u>FOR OFFICE USE ONLY</u>
Facility # 2-032321
Permit # 01154-2014UPG
Request Rec'd 12/01/2014
Amended Date
Approval Date 12/1/2014 JC
Permit Expires 6/1/2015

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Con-Way Central Express C/O CNF, Inc.          401 West Touhy          Des Plaines, IL 60016</p> <p>Contact: Casey Alexander (503) 205-7749</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Conway Freight          401 W Touhy Avenue          Des Plaines, Cook Co., IL</p> <p>Contact: Tom Mullaney (847) 390-6270</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 2) - 20,000 gallons, (TK # 3, 4) - 2,500 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:*
- (d) *Product to be stored in each tank:* (TK # 1, 2) - Diesel Fuel, (TK # 3) - Used Oil, (TK # 4) - New Oil
- (e) *Type of leak detection being used:*  
*Tank:* (TK # 1, 2, 3, 4) - (Installing) Automatic Tank Gauging Veeder Root TLS 450 console only (to replace the existing console). The existing probes will remain. **See 175.630(d)(4) - printers.**  
*Piping:*
- (f) *Corrosion Protection being used:*  
*Tank:*  
*Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

**(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
<p>AmpSCO Service Corp          730 Creel Dr.          Wood Dale, IL 60191</p>	<p>Contact Person: Chris Derro          Phone: 7087959052          Contractor Registration # IL-002399 Exp. 12/20/2015</p>

Sincerely,

Jim Coffey