



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

<u>FOR OFFICE USE ONLY</u>
Facility # 2-010900
Permit # 01164-2014UPG
Request Rec'd 12/05/2014
Amended Date
Approval Date 12/5/2014 JC
Permit Expires 6/5/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Norouz Enterprises, Inc. 940 Indiana Springs Lane Buffalo Grove, IL 60089</p> <p>Contact: John Yousefzai</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Citgo 41490 US Rt. 41 & 173 Wadsworth, Lake Co., IL</p> <p>Contact: Sanjuana Mata (847) 395-4400</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 8, 9, 10, 11) - 12,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 8, 9, 10, 11) - (Installing) nipple fittings and couplings to adjust the existing shear valves to the proper height under dispenser 11/12 only. Universal anchor mounting brackets will be installed to secure the existing shear valves under dispensers 1,2,3,4 only, (TK # 8, 9, 10, 11) - (Installing) Dispenser Sumps containment FRP under dispenser # 13/14 only.
- (d) *Product to be stored in each tank:* (TK # 8, 9, 10) - Gasoline, (TK # 11) - Diesel Fuel
- (e) *Type of leak detection being used:*
 Tank:
 Piping:
- (f) *Corrosion Protection being used:*
 Tank:
 Piping:
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES: This permit replaces amended permit #00194-2014UPG. All equipment remains the same.

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	
<p>K-Plus Mechanical, Inc. 24317 W. 143rd. St. #113 Plainfield, IL 60544</p>	<p>Contact Person: Gerald Ford Phone: (815) 230-3040</p> <p>Contractor Registration # IL-002335 Exp. 02/09/2016</p>

Sincerely,

Jim Coffey

