



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020

**PIPING ONLY!!!**

<b>FOR OFFICE USE ONLY</b>
Facility # 6-017875
Permit # 00408-2013REM
Request Rec'd 05/09/2013
Amended Date
Approval Date 5/9/2013 DS
Permit Expires 11/9/2013

**Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          St. Mary's Good Samaritan, Inc.          400 North Pleasant          Centralia, IL 62801          Contact: Stover Harold Jr (618) 532-6731</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          St. Mary's Hospital          400 North Pleasant Avenue          Centralia, Marion Co., IL          Contact: Howard Jones (618) 532-6731</p>
--	---

**(3) REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed:* (TK # 7) - 6,000 gallons
- (b) *Description/location of piping being removed:*
- (c) *Product stored in each tank:* (TK # 7) - Diesel Fuel
- (d) *Reason of tanks being removed:* **Steel piping supplying generator being removed to be replaced with DW piping**
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used:* (TK # 7)

**(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.**

**(5) SPECIAL CONTINGENCIES:** Piping only!

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
United Petroleum Service, Inc. 1458 Collins Street Saint Louis, MO 63102	Contact Person: Harvey Stokes Phone: Contractor Registration # Exp.

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Division File  
 (Rev. - 9/10)