



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-018605
Permit # 00833-2010UPG
Request Rec'd 07/16/2010
Amended Date
Approval Date 7/20/2010 JC
Permit Expires 1/20/2011

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: TA Operating, LLC 24601 Center Ridge Road, Suite 200, d/b/a Travel Centers of America, Inc. Westlake, OH 44145 Contact: Tom CareyClark (309) 827-4676	(2) FACILITY - name and address where tanks are located: Lakar Enterprises 21 Romines Drive Morris, Grundy Co., IL Contact: Brent Scheoder (815) 942-5690
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired:* (TK # 1, 2, 3) - 12,000 gallons
- (b) Type of tanks:* (TK # 1, 2, 3) - (Installing) Other Fibrelite FRP sumps for each tank, transition sump, and all dispensers.
- (c) Type of piping:* (TK # 1, 2, 3) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX to replace all existing piping and to accommodate the new dispenser layout.
- (d) Product to be stored in each tank:* (TK # 1) - Bio-Diesel, (TK # 2, 3) - Diesel Fuel
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:* (TK # 1, 2, 3) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at all tank sumps, transition sump, and all dispenser sumps, (TK # 1, 3) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350 (for the lines of tank 1 & 3 only - since tank #2 will be a "siphon" tank without a submersible pump).
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:* (TK # 1, 2, 3) - (Installing) Fiberglass Non-Corrosive
- (g) Spill containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Adam Balcazar Phone: Contractor Registration # Exp.

Sincerely,

