

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

FOR OFFICE USE ONLY

Facility # 2-013106
Permit # 00778-2010UPG
Request Rec'd 07/08/2010
Amended Date
Approval Date 7/8/2010 JC
Permit Expires 1/8/2011

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Milprint Illinois, LLC 3550 Moser Street Oshkosh, WI 54901	Milprint Illinois, LLC 5303 St. Charles Road Bellwood, Cook Co., IL
Contact: Brian Fuhrer	Contact: Allison Diddens

(3) <u>UPGRADE OR REPAIR OF TANKS:</u>

- (a) Number and size of tanks being upgraded or repaired: (TK # 5, 6, 7, 8, 9) 2,000 gallons
- **(b)** Type of tanks: (TK # 5, 6, 7, 8, 9) (Installing) Other Fibrelite FRP transition sump located next to the building where the piping will transition from underground to above ground inside the building.
- (c) Type of piping: (TK # 5, 6, 7, 8, 9) (Installing) Steel Single Wall primary product Piping from the tanks to the transition sump where it will then become aboveground piping inside the building, (TK # 5, 6, 7, 8, 9) (Installing) Fiberglass Single Wall Piping for secondary containment of the underground piping from the tanks to the transition sump.
- (d) Product to be stored in each tank: (TK # 5, 6, 7, 8, 9) Solvent
- (e) Type of leak detection being used:

Tank:

Piping: (TK # 5, 6, 7, 8, 9) - (Installing) European with No Test Req Suction, (TK # 5, 6, 7, 8, 9) - (Installing) Piping Sump Sensor Interstitial Monitoring Incon TS 1001 at the transition sump only.

(f) Corrosion Protection being used:

Tank:

Piping:

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES**:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:		
	Contact Person: Phone:	
	Contractor Registration # Exp.	

Janu J Coffey

Sincerely,

Jim Coffey

(Rev. - 1/98)