



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-011337
Permit # 00765-2010ABN
Request Rec'd 07/01/2010
Amended Date
Approval Date 7/2/2010 JC
Permit Expires 1/2/2011

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Waukegan IL Hospital Company, LLC 7100 Commerce Way, Suite 100, d/b/a Vista Medical Center East Brentwood, TN 37027 Contact: Gary D. Newson	(2) FACILITY - name and address where tanks are located: Vista Medical Center West 2615 Washington Street Waukegan, Lake Co., IL Contact: Bob Henne (847) 360-2097
---	---

(3) ABANDONMENT IN PLACE OF TANKS:

- (a) *Number and size tanks being abandoned:* (TK # 2, 3) - 20,000 gallons
(b) *Location of tanks being abandoned:* CONTAMINATED SITE! IEMA Number: H20100699

- (4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.
- (5) **SPECIAL CONTINGENCIES:** The tanks are in poor condition and will be replaced by a new tank in another location on site. The tanks are located within a concrete vault under a driveway next to the building foundation of which may rely on the tanks for structural integrity. The removal / dismantalling of the tanks if attempted, would also interfere with critical utilities. Heavy tank removal equipment cannot be supported within 50' of the UST's due to the existence of a basement. The UST's directly adjoin the West load bearing wall of the energy plant. Fire main piping is also in close proximity to the tanks.
- (6) The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Crowne Industries, Ltd. 2511 West Schaumburg Road, #358 Schaumburg, IL 60194	Contact Person: Robert Sumoski Phone: (630) 497-9009 Contractor Registration # Exp.
--	---

Sincerely,

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)