



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

**Amended**

FOR OFFICE USE ONLY

Facility # 7-023238  
Permit # 00657-2010INS  
Request Rec'd 06/02/2010  
**Amended Date 06/21/2010**  
Approval Date 6/3/2010 JC  
Permit Expires 12/3/2010

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  AA Investments & Holdings, Inc. 3900 Sycamore Street Cairo, IL 62914  Contact: Ali Abukhdair (618) 306-0117	<b>(2) FACILITY</b> - name and address where tanks are located:  Cut-Mart #7 201 Main Street Mound City, Pulaski Co., IL  Contact: Ali Abukhdair (618) 748-9245
--	---

**(3) INSTALLATION OF TANKS:**

- (a) **Number and size of tanks being installed:** (TK # 4) - 7,000 gallons, (TK # 5) - 3,000 gallons . These two tanks comprise one compartment tank.
- (b) **Type of tanks:** (TK # 4, 5) - (Installing) Fiberglass Double Wall XERXES
- (c) **Type of piping:** (TK # 4, 5) - (Installing) Flexible Double Wall OPW Pisces . There is an existing tee fitting and short section of existing piping at the first dispenser that a run of new piping will fit into. The small portion of the existing piping and tee is double wall.
- (d) **Product to be stored in each tank:** (TK # 4) - Gasoline, (TK # 5) - Diesel Fuel
- (e) **Type of leak detection being used:**  
**Tank:** (TK # 4, 5) - (Installing) Interstitial Monitoring Veeder Root TLS 350 , (TK # 4, 5) - (Installing) Automatic Tank Gauging Veeder Root TLS 350 (the existing console will remain, and they will re-use the probes from the removed tanks).  
**Piping:** (TK # 4, 5) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 , (TK # 4, 5) - Electronic Pressurized Line Leak Detection Veeder Root TLS 350 from the removed tanks will be re-used for these two tanks. The interstitial sensors will be installed in all dispenser sumps and for each tank sump.
- (f) **Corrosion Protection being used:**  
**Tank:** (TK # 4, 5) - (Installing) Fiberglass Non-Corrosive  
**Piping:** (TK # 4, 5) - (Installing) Flexible Non-Corrosive
- (g) **Spill containment devices:**
- (h) **Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.

- (5) **GENERAL REQUIREMENTS:** There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

**(6) SPECIAL CONTINGENCIES:**

<b>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b>          Contact Person: Andrew Clark Phone:  Contractor Registration #    Exp.
---

Sincerely,

James J. Coffey

cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 1/98)