



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

Amended

FOR OFFICE USE ONLY
Facility # 2-001847
Permit # 00476-2010UPG
Request Rec'd 04/28/2010
Amended Date 06/15/2010
Approval Date 4/29/2010 JC
Permit Expires 10/29/2010

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Lake Zurich School Community Unit School District 95 400 S. Old Rand Rd. Lake Zurich, IL 60047 Contact: Jeff King	(2) FACILITY - name and address where tanks are located: Lake Zurich Community Unit School District 95 66 Church Street Lake Zurich, Lake Co., IL Contact: Eakright Lee (708) 438-2831
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 8) - 2,000 gallons, (TK # 9) - 8,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 8, 9) - (Installing) Positive Shutoff Valves, **(TK # 8, 9) - (Installing) Flex Connector Steel at the tank sumps only.** The two ball valves will be installed in the product lines for testing. Contractor is also replacing each tank sump with new OPW Flexworks sumps. Piping will be re-fitted at the sumps to accommodate the new sumps. New entry boots will also be installed. Manways will be installed for existing ancillary equipment access.
- (d) *Product to be stored in each tank:* (TK # 8) - Gasoline, (TK # 9) - Ultra Low Sulfur Diesel
- (e) *Type of leak detection being used:*
Tank:
Piping:
- (f) *Corrosion Protection being used:*
Tank:
Piping:
- (g) *Spill containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	Contact Person:
	Phone:
	Contractor Registration # Exp.

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File

