



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

FOR OFFICE USE ONLY  
Facility # 2-005475  
Permit # 00393-2013UPG  
Request Rec'd 05/07/2013  
Amended Date  
Approval Date 5/7/2013 JC  
Permit Expires 11/7/2013

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Chicago Executive Airport 1020 South Plant Road Wheeling, IL 60090  Contact: Dennis Rouleau (847) 537-1200	<b>(2) FACILITY</b> - name and address where tanks are located:  Signature Flight Support 1126 S. Milwaukee Avenue Wheeling, Cook Co., IL  Contact: Tim Latendresse (847) 537-1200
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

**(a) Number and size of tanks being upgraded or repaired:** (TK # 12) - 20,000 gallons

**(b) Type of tanks:**

**(c) Type of piping:** (TK # 12) - (Installing) Transition Sump FRP fiberglass at the new dispenser location , (TK # 12) - (Installing) partial Fiberglass Double Wall Ameron Dualoy 3000/LCX from the existing transition sump where it will tee towards the new dispenser that will be located approximately 60' east of the tank field. This new piping will transition to a short amount of above ground piping to accommodate the new dispenser

**(d) Product to be stored in each tank:** (TK # 12) - Aviation Fuel

**(e) Type of leak detection being used:**

**Tank:**

**Piping:** (TK # 12) - (Installing) Piping Sump Sensors Interstitial Monitoring Pneumercator LC1000 at the existing transition sump and at the new transition / dispenser sump.

**(f) Corrosion Protection being used:**

**Tank:**

**Piping:** (TK # 12) - (Installing) partial Fiberglass Non-Corrosive

**(g) Spill containment devices, piping, and dispenser containment devices:**

**(h) Overfill prevention devices:**

**(i) Manway accessible at grade:**

**(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  Schaumburg, IL 60194	Contact Person: Robert Sumoski Phone: (630) 497-9009  Contractor Registration # Exp.
---	---

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)