



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-021199
Permit # 00667-2010UPG
Request Rec'd 06/04/2010
Amended Date
Approval Date 6/4/2010 JC
Permit Expires 12/4/2010

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: True North Energy, LLC 5565 Airport Highway Toledo, OH 43635 Contact: David P. Nye (630) 379-8463	(2) FACILITY - name and address where tanks are located: True North Location 1918 2135 Green Bay Rd. Highland Park, Lake Co., IL Contact: Ifetekhar Baqai (847) 432-0055
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired:* (TK # 6, 7, 8) - 10,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 6, 7, 8) - (Installing) Flexible Double Wall Universal Petro Pipe to replace all existing product piping. All vapor and vent piping will also be replaced with UPP single wall. New sumps will also be installed at the tank fill and turbine.

(d) *Product to be stored in each tank:* (TK # 6, 7, 8) - Gasoline

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 6, 7, 8) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at all submersible sumps and all dispenser sumps if there are none present. If there are presently sensors in these sumps, they will be re-used. Also, the existing line leak detectors will be re-used.

(f) *Corrosion Protection being used:*

Tank:

Piping: (TK # 6, 7, 8) - (Installing) Flexible Non-Corrosive

(g) *Spill containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Jack Meek Phone: Contractor Registration # Exp.
--

Sincerely,

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)