



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<u>FOR OFFICE USE ONLY</u>
Facility # 4-037246
Permit # 00524-2010UPG
Request Rec'd 05/06/2010
<b>Amended Date 05/20/2010</b>
Approval Date 5/7/2010 JC
Permit Expires 11/7/2010

## Amended

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:           Tri-Star Marketing, Inc.          2211 West Bradley Avenue, P.O. Box 9279          Champaign, IL 61826-9279           Contact: Kathy Delsignore (217) 367-8307 Ext. 133</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:           Mobil Super Pantry #13          2412 South Main Street          Bloomington, McLean Co., IL           Contact: Chuck Cline (217) 367-8387 Ext. 133</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 20,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* **(TK # 1) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/L** between the two southwest dispensers only (to replace the existing section). This piping will be installed through the existing secondary chase piping.
- (d) *Product to be stored in each tank:* (TK # 1) - Gasoline
- (e) *Type of leak detection being used:*  
  - Tank:*
  - Piping:* (TK # 1) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at the two southwest dispensers only.
- (f) *Corrosion Protection being used:*  
  - Tank:*
  - Piping:*
- (g) *Spill containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

**(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p> <p align="right">Contact Person:          Phone:           Contractor Registration #    Exp.</p>
---

Sincerely,

Jim Coffey