



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY
Facility # 2-019869
Permit # 00374-2013UPG
Request Rec'd 05/03/2013
Amended Date
Approval Date 5/3/2013 JC
Permit Expires 11/3/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Underwriters Laboratories, Inc. 333 Pfingsten Rd. Northbrook, IL 60062 Contact: Thomas Buchanan (847) 272-8800	(2) FACILITY - name and address where tanks are located: Underwriters Laboratories, Inc. 333 Pfingsten Road Northbrook, Cook Co., IL Contact: Mike Kaminsky (847) 815-1604
--	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 24, 25, 26) - 1,000 gallons

(b) Type of tanks:

(c) Type of piping: (TK # 24, 25, 26) - (Installing) Dispenser Sumps containment FRP and new tank sumps, (TK # 24, 25, 26) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX to replace the existing product piping, (TK # 24, 25, 26) - (Installing) Fiberglass Single Wall Piping Ameron to replace the existing vent piping.

(d) Product to be stored in each tank: (TK # 24) - Diesel Fuel, (TK # 25, 26) - Gasoline

(e) Type of leak detection being used:

Tank:

Piping: (TK # 24, 25, 26) - (Installing) new Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at the two dispenser sumps, and re-installing the existing tank sump sensors, (TK # 24, 25, 26) - (Installing) European with No Test Req Suction, along with installing two new dispenser european suction pumps.

(f) Corrosion Protection being used:

Tank:

Piping: (TK # 24, 25, 26) - (Installing) Fiberglass Non-Corrosive

(g) Spill containment devices, piping, and dispenser containment devices: (TK # 24, 25, 26) - (Installing) Manhole Pre-manufactured OPW 1-2100

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Wheeling, IL 60090-3906	Contact Person: Larry Cherner Phone: (847) 465-4000 Contractor Registration # Exp.
--	--

Sincerely,

Jim Coffey