



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 2-027733  
Permit # 00561-2010UPG  
Request Rec'd 05/12/2010  
Amended Date  
Approval Date 5/13/2010 JC  
Permit Expires 11/13/2010

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Central DuPage Hospital 25 N. Winfield Road Winfield, IL 60199 Contact: Steve Robinson (630) 933-6327	<b>(2) FACILITY</b> - name and address where tanks are located: Central DuPage Hospital 25 N. Winfield Road Winfield, Du Page Co., IL Contact: Steve Robinson (630) 933-6327
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 9) - 20,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 9) - (Installing) Flexible Double Wall NUPI Smartflex - This will consist of a total of 4 new lines for this tank - 2 new ones for supply and return, and 2 new ones for the filter system supply and return. The existing 2 lines for this tank will remain as spares and will continue to be monitored.
- (d) *Product to be stored in each tank:* (TK # 9) - Diesel Fuel
- (e) *Type of leak detection being used:*  
*Tank:*  
*Piping:* (TK # 9) - (Installing) American with Annual Prec Line Testing Suction , (TK # 9) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at tank sump and at transition sump.
- (f) *Corrosion Protection being used:*  
*Tank:*  
*Piping:* (TK # 9) - (Installing) Flexible Non-Corrosive
- (g) *Spill containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>   Contact Person: Phone:  Contractor Registration #    Exp.
---

Sincerely,

Jim Coffey

