



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY
Facility # 2-010863
Permit # 00371-2013UPG
Request Rec'd 05/03/2013
Amended Date
Approval Date 5/3/2013 JC
Permit Expires 11/3/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Skop Properties, LLC 7328 W. Crain Niles, IL 60714 Contact: George Gauriilopoulos (847) 712-1189	(2) FACILITY - name and address where tanks are located: B&G Oil, Inc. 451 Glenview Road Glenview, Cook Co., IL Contact: George Gavriilopoulos (847) 657-7789
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired:* (TK # 2, 3, 4) - 10,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 2, 3, 4) - (Installing) Fiberglass Double Wall A.O. Smith to replace old product piping and to accommodate the reconstruction and re-positioning of the dispenser islands. Also, the piping for tanks 1 and 2 will be manifolded together (there are existing submersible pumps and existing line leak detectors. , (TK # 2, 3, 4) - (Installing) Submersible Sumps containment FRP, (TK # 2, 3, 4) - (Installing) Dispenser Sumps containment FRP

(d) *Product to be stored in each tank:* (TK # 2, 3, 4) - Gasoline

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 2, 3, 4) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at the dispenser sumps only. The existing submersible sump sensors will be re-used. The existing line leak detectors will be re-used.

(f) *Corrosion Protection being used:*

Tank:

Piping: (TK # 2, 3, 4) - (Installing) Non-corrosive fiberglass

(g) *Spill containment devices, piping, and dispenser containment devices:* (TK # 2, 3, 4) - (Installing) Manhole Pre-manufactured OPW 1C-2100C-DEVR

(h) *Overfill prevention devices:* (TK # 2, 3, 4) - (Installing) Overfill Drop Tube Valve OPW 71SO-400C

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Chicago Heights, IL 60411	Contact Person: Raymond Kirchner Phone: (708) 758-3222 Ext. 12 Contractor Registration # IL-194 Exp.
--	--

Sincerely,

