



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

Amended

FOR OFFICE USE ONLY
Facility # 3-017404
Permit # 00474-2010UPG
Request Rec'd 04/28/2010
Amended Date 05/10/2010
Approval Date 4/29/2010 JC
Permit Expires 10/29/2010

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: 7-Eleven, Inc. P.O. Box 711, Dallas, TX 75221-0711 Contact: Kashif Sheika (214) 826-0711	(2) FACILITY - name and address where tanks are located: 7-Eleven Store #24458 2930 16th Street Moline, Rock Island Co., IL Contact: Peggie Betz
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 10,000 gallons, (TK # 4, 5) - 6,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1, 4, 5) - (Installing) Fiberglass Single Wall Piping, (TK # 1, 4, 5) - **(Installing) Flexible Double Wall A.P.T. Poly Tech P175SC** - The single wall fiberglass piping will be for replacement of the existing vent piping. New submersible sumps and entry boots will also be installed. **The double wall fiberglass piping will replace the existing product piping between each tank sump and between dispensers 1/2 and 3/4 only.**
- (d) *Product to be stored in each tank:* (TK # 1, 4, 5) - Gasoline
- (e) *Type of leak detection being used:*
Tank:
Piping: (TK # 1, 4, 5) - (Installing) Piping Sump Sensors Interstitial Monitoring Incon TSP ULS at dispenser sumps 1/2 and 3/4 only. According to our records there are existing sensors in each submersible sump. The product piping to dispenser 5/6 will remain.
- (f) *Corrosion Protection being used:*
Tank:
Piping:
- (g) *Spill containment devices:*
- (h) *Overfill prevention devices:* - to include the removal of the existing ball float vent valves.
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Steve Cox Phone: Contractor Registration # Exp.

Sincerely,

