



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

Amended

FOR OFFICE USE ONLY
Facility # 3-033811
Permit # 00292-2010UPG
Request Rec'd 03/18/2010
Amended Date 04/28/2010
Approval Date 3/18/2010 JC
Permit Expires 9/18/2010

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: 7-Eleven, Inc. P.O. Box 711, Dallas, TX 75221-0711 Contact: Kashif Sheika (214) 826-0711	(2) FACILITY - name and address where tanks are located: 7-Eleven Store #34462 3718 39th Avenue Drive Moline, Rock Island Co., IL Contact: Elizabeth Patterson (309) 762-9580
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 10,000 gallons, (TK # 2, 3) - 6,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1, 2, 3) - (Installing) Fiberglass Single Wall vent piping to replace all existing vent piping. The piping will also be re-directed from the present location. **New submersible sumps and entry boots will also be installed. The existing product lines will remain; however they will be disconnected and pulled back from the existing sumps and then re-installed in the new sumps.**
- (d) *Product to be stored in each tank:* (TK # 1, 2, 3) - Gasoline
- (e) *Type of leak detection being used:*
Tank:
Piping:
- (f) *Corrosion Protection being used:*
Tank:
Piping:
- (g) *Spill containment devices:*
- (h) *Overfill prevention devices:* , and the removal of the existing ball float vent valves.
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Steve Cox Phone: Contractor Registration # Exp.

Sincerely,

