



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-000972
Permit # 00467-2010ABN
Request Rec'd 04/26/2010
Amended Date
Approval Date 4/28/2010 JC
Permit Expires 10/28/2010

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Reavis High School District #220 6034 West 77th Street Burbank, IL 60459 Contact: tim Donohoe (708) 599-7200	(2) FACILITY - name and address where tanks are located: Reavis High School District #220 6034 West 77th Street Burbank, Cook Co., IL Contact: Tim Donohoe (708) 599-7200
--	--

(3) ABANDONMENT IN PLACE OF TANKS:

(a) Number and size tanks being abandoned: (TK # 3) - 8,000 gallons, (TK # 5) - 10,000 gallons

(b) Location of tanks being abandoned: CONTAMINATED SITE! IEMA Number: H20091209

- (4)** This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.
- (5) SPECIAL CONTINGENCIES:** IEMA number is for tank #3. Site assessment is on file. Tank #3 is adjacent to an electrical transformer, and has underground electric utility lines running over the top of the tank. Tank #5 is 5' from building foundation, right next to an electrical transformer and underground utility electrical line, and has a large trash compactor located over the top of the tank. Removal of these tanks may undermine the integrity of the power lines and transformers. Tank #5 location is noted as clean.
- (6)** The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> R. W. Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: William Collins Phone: (708) 458-6868 Contractor Registration # IL-772 Exp.
---	---

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)