



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
 Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

FOR OFFICE USE ONLY
 Facility # 4-024951
 Permit # 00296-2010UPG
 Request Rec'd 03/18/2010
Amended Date 04/27/2010
 Approval Date 3/19/2010 JC
 Permit Expires 9/19/2010

Amended

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Tri-Star Marketing, Inc. 2211 West Bradley Avenue, P.O. Box 9279 Champaign, IL 61826-9279 Contact: Kathy Delsignore (217) 367-8307 Ext. 133</p>	<p>(2) FACILITY - name and address where tanks are located: Super Pantry 44 810 West Green Urbana, Champaign Co., IL Contact: Cline Chuck (217) 367-8386</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 2) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1, 2) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX , (approximately 10' to accommodate the new E-85 dispenser). **Also installing approximately 3' of Smith double wall fiberglass at the submersible to accommodate the installation of a new submersible sump for tank #1 only. (SEE SITE PLAN, AND CONTINGENCIES SECTION).**
- (d) *Product to be stored in each tank:* (TK # 1, 2) - Gasoline
- (e) *Type of leak detection being used:*
 - Tank:** (TK # 1) - Existing TLS 350 with CSLD to remain; however, the tank probe will be changed to a VR #846391-407 Mag Plus probe for alternative fuels.
 - Piping:** (TK # 1) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 (#794380-430) at the new E-85 dispenser sump and at the submersible sump only. The existing sensor at the submersible will be replaced by the new sensor for compatibility with E-85.
- (f) *Corrosion Protection being used:*
 - Tank:**
 - Piping:** (TK # 1, 2) - (Installing) partial fiberglass non-corrosive.
- (g) *Spill containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> <p>Contact Person: Phone: Contractor Registration # Exp.</p>

Sincerely,

Jim Coffey

